



**Energy baseline development, tariff study and tool, O&M
plan and manual and capacity building for the 500 kWp solar
PV mini-grid in Bissorã, Guinea Bissau**

TASK 2 – Energy baseline

Final report

Prepared for:

UNIDO



April 2018

Project:	Energy baseline development, tariff study and tool, O&M plan and manual and capacity building for the 500 kWp solar PV mini-grid in Bissorã, Guinea Bissau
Client:	United Nations Industrial Development Organization
Consultant:	Trama TecnoAmbiental
Project code	UNIDO Purchase order (PO) number 3000050690 TTA Project code CI-17-0028

ENERGY BASELINE REPORT

DELIVERABLE #2: Energy Baseline Report

Related Documents	Type of document	Draft/final	Date of submission
Inception report	PDF	Final	19/9/2017
Annex 1 – Chief questionnaire	Word	Draft	19/9/2017
Annex 2 – End-user questionnaire	Word	Draft	19/9/2017
Annex 3 – IPP questionnaire	Word	Draft	19/9/2017
Task 2 Report - Energy baseline v.2	Word	Draft	12/1/2018
Task 2 Report - Energy baseline v.5	Word	Draft	22/2/2018

Financed by:	United Nations Industrial Development Organization
---------------------	--

PRESENTATION

This report is the Deliverable #2 from the technical assistance offered to UNIDO for the development of the 500 kWp solar PV mini-grid in Bissorã, Guinea Bissau

The report has been directed by Eng. Alberto Rodríguez Gómez. The authors of this report are Marilena Lazopoulou and Diego Perez.

Table of Contents

List of Figures	1
List of Tables	2
Table of Acronyms	3
1. Introduction	4
2. Methodology.....	5
3. Data gathering.....	6
3.1. Population and growth.....	6
3.2. Energy uses and future needs	7
3.3. Current situation of distribution grid	10
4. Demand estimation.....	10
4.1. General assumptions.....	10
4.2. Individual load profiles	11
5. Energy baseline results	12
5.1. Base scenario.....	12
5.2. Intermediate scenario	14
5.3. Future scenario.....	16
6. Conclusions	18
Annex: Interview results	19

List of Figures

Figure 1: Flowchart for energy baseline estimation	5
Figure 2: Solar street light (left) and grid-connected one (right) in the administrative district of Bissorã.....	7
Figure 3: Aspect of a typical commercial street in Bissorã	8
Figure 4: General aspect of wood processing factory (left) and electrical cabinet (right).....	9
Figure 5: LCD universal charger in Bissorã	9
Figure 6: Individual load profiles for energy baseline.....	11
Figure 7: Bissorã load curve under Base Scenario	13
Figure 8: Pie chart of consumer types under Base Scenario.....	14
Figure 9: Bissorã load curve under Intermediate Scenario.....	15
Figure 10: Pie chart of consumer types under Intermediate Scenario	16
Figure 11: Bissorã load curve under Future Scenario	17
Figure 12: Pie chart of consumer types under Future Scenario.....	18

List of Tables

Table 1: Bissoră population per neighbourhood according to 2009 census.....	6
Table 2: Institutions potentially to connect to the mini-grid.....	7
Table 3: Businesses potentially to connect to the mini-grid.....	10
Table 4: Energy demand assessment under Base Scenario.....	12
Table 5: Energy demand assessment under Intermediate Scenario.....	14
Table 6: Energy demand assessment under Future Scenario.....	16
Table 7: Summarised results of Energy Baseline.....	18

Table of Acronyms

Abbreviations	Explanation
ABREC-SABER	African Biofuel and Renewable Energy Company
ADPP	Ajuda de Desenvolvimento de Povo para Povo
ARPU	Average revenues per user
ACDB	Associação Comunitária de Desenvolvimento de Bambadinca
ATP	Ability to pay
ECREEE	ECOWAS Centre for Renewable Energy and Energy Efficiency
EU	European Union
GEF	Global Environmental Facility
GHG	Greenhouse Gas
IPP	Independent power producer
KPI	Key performance indicator
kWp	Kilowatt peak (refers to installed photovoltaic capacity in STC)
MWh	Megawatt-Hour
O&M	Operation and maintenance
PV	Photovoltaic
PSH	Peak sun hours
STC	Standard test conditions
TTA	Trama TecnoAmbiental
UF	Utilisation factor
UNIDO	United Nations Industrial Development Organization
WAEMU/UEMOA	West African Economic and Monetary Union
WTP	Willingness to pay

1. Introduction

Following the Call for Proposals issued by the United Nations Industrial Development Organization (UNIDO) in July 2017, Trama TecnoAmbiental (TTA) was awarded a contract for the “Energy baseline development, tariff study and tool, O&M plan and manual and capacity building for the 500 kWp solar PV mini-grid in Bissorã, Guinea Bissau”. The main objective of this project is to develop the soft issues around the 500 kWp solar PV mini-grid to ensure a sustainable and durable project.

This project is part of the Global Environmental Facility (GEF). The GEF Project (ID 5331) entitled “Promoting investments in small to medium scale renewable energy technologies in the electricity sector of Guinea-Bissau” is executed by UNIDO in close partnership with the Ministry of Energy and Industry of Guinea Bissau, the ECOWAS Centre for Renewable Energy and Energy Efficiency (ECREEE) and the Small Island Sustainable Energy and Climate Resilience Organization (SIDS DOCK).

In this context, UNIDO, the West African Economic and Monetary Union (WAEMU/UEMOA) and the African Biofuel and Renewable Energy Company (ABREC-SABER) are partnering for the construction of a solar PV hybrid mini-grid for the city of Bissorã with a total installed solar PV capacity of 500 kWp. The company Prosolia Africa has been contracted to undertake the required civil works and turn-key installation of the power station.

The city of Bissorã is a peri-urban hub and an important administrative centre of the Oio region. According to a preliminary survey, Bissorã presents economic dynamism thanks to its administrative role. It has around 14.000 inhabitants (1.300 households, with an average of 11 inhabitants per household), 275 businesses including shops, hotels, 1 hospital, 10 schools, 1 police station, 4 administrative offices, wood saws, a youth centre as well as 4 mosques and churches. Currently some have private gensets or are connected to electricity services through informal independent power producers (IPP).

Through a desk study of previous work in Bissorã, reference projects in the area (i.e. Bambadinca mini-grid) and a field visit, TTA has elaborated an energy baseline for Bissorã town. The present study further examines three scenarios. A *base scenario* considering 470 connections (equal to the number of meters procured for the initial phase of the project as of Q1 2018) and the current demand of the potential end-users found during the site visit. A second scenario (*intermediate scenario*) estimates the maximum number of connections that the 500 kWp mini-grid can cover only with solar power and a third one (*future scenario*) calculates the total potential demand of Bissorã and the possible necessities of expansions of the generation plant and distribution line.

2. Methodology

The methodology followed by TTA for the definition of the energy baseline combines real data collected during two site visits (2-6/10/2017 and 7-8/2/2018), consumption data from Bambadinca’s mini-grid (covering the period between December 2016 and June 2017), as well as various assumptions based on TTA’s long experience in rural electrification. The flowchart below describes the process that has been followed in order to build the energy baseline of the Bissõra community.




Figure 1: Flowchart for energy baseline estimation

*The energy daily allowances (EDA) are TTA’s standardised energy tiers assigned to the connections and are multiples of the basic EDA of 550 Wh/day

3. Data gathering

3.1. Population and growth

Table 1 shows the population of Bissorã according to the 2009 census, distributed by neighbourhoods (“bairros”).

Table 1: Bissorã population per neighbourhood according to 2009 census

#	Neighbourhood	Population (2009 census)
1	Joaquim N’com 1	390
2	Joaquim N’com/N’tchantcha	639
3	Joaquim N’com/Madina	874
4	Joaquim N’com/Argentina (incl. Veterinaria)	944
5	Braga 1	1239
6	Braga 2	937
7	Sintcha	562
8	Praça	475
9	Santa Luzia	982
10	Santa Luzia (2)	718
11	Gã- Cemiteiro	239
12	Gã-Djugude	279
13	Gã-Banana	325
14	Missira	341
15	Outra Banda	491
16	Touba	85
	TOTAL	9.520

According to collected information, between 2009 and 2017, population in Sintcha has increased by 130% and in Santa Luzia 73%, or around 100% as an average in 8 years. We can assume a total increase in Bissorã’s population of 50% between 2009 and 2017 as a conservative estimation or 5.2% per year, totalling to **14.280** inhabitants.

Assuming 11 people per household (experience from Bambadinca, whereas otherwise is 6 for Guinea Bissau), the final number of households in Bissorã considered for the study is **1.298**.

Note: The previous highlighted data of 1.298 households was confirmed by the participants during the Energy Baseline Workshop that took place in Bissau on the 8th of February 2018.

3.2. Energy uses and future needs

Currently, the main economic activities in Bissorã are agriculture, commerce and services, since Bissorã is a main administrative hub for the northern region of the country. Typical energy uses at the moment are lighting and product conservation.

There is no single typical light bulb used at the moment; during the site visits different ones were observed ranging from efficient ones to up to 60 W. However efficient LED of 8-15-20 W can be purchased locally starting from 5000 CFA.

There are two types of fridges identified: the ones consuming 160 W and 1.1 kWh over 24 hours (46 W on average per hour) and the ones consuming 200 W and 2 kWh over 24 hours (80 W on average per hour). They cost 490.000 XOFs (746 EUR) in Bissau.

Institutional:

The administration buildings include ministry buildings, the house of justice, police, etc. They do not have any connection to thermal units at the moment and their internal wiring is old and would need revision in order to connect to the mini-grid (estimated cost of upgrade between 40 and 120 €). Nonetheless, from an interview conducted to the house of justice, they are eager to receive lights, computers, AC units and photocopy machines.

Other institutional users include religion places, schools and a hospital, as well as a water pump, currently working on diesel generator and foreseen to connect to the mini-grid. Additionally, there are water wells but are not planned to switch to electric ones and connect.

Street lighting has been already installed at some parts along the distribution line. There are also streetlights based on individual solar panels, as seen in the following image.



Figure 2: Solar street light (left) and grid-connected one (right) in the administrative district of Bissorã

The total number of potential institutional connections is seen below:

Table 2: Institutions potentially to connect to the mini-grid

Institutions	Number
Churches	2
Mosques	3
Education centres (daily)	9
Boarding schools	1

Institutions	Number
Health facilities	1
Administrative (Police, DRA, court)	3
Water pump	1
Street light	1
TOTAL	21

Commercial:

There are around 272 commercial users, most of which already have a connection to a private or shared genset (informal mini-grid), as well as a small solar panel for lighting. Besides small shops and restaurants, anchor loads identified are a wood processing factory, a telecommunication tower, a water pump and the market. Other relatively large consumers would be the pharmacies, the veterinary and the hotel.

The fee for 4 hours of service through the informal mini-grids is 15.000 FCFA/month supplying lighting and plugs or 25.000 FCFA/month for additionally having a fridge (“arca”). It can be assumed that with a continuous electricity service from the mini-grid, two thirds (2/3) of the commercial users shall have fridges. A typical commercial street is shown below.



Figure 3: Image of a typical commercial street in Bissorã

The largest potential consumer identified in Bissora town is the wood processing factory (“serralheria”), having shown interest in connecting to the mini-grid. It consists of a compound with various heavy equipment currently supplied by a 120 kW genset, consuming 60 L of diesel per day during 8 working hours, all year round.



Figure 4: General aspect of wood processing factory (left) and electrical cabinet (right)

There are two telecommunication stations in the entrance of the village, one from MTN running on a private genset and one from Orange with a 12 kWp PV with storage. For the purposes of this energy baseline, it is assumed that the MTN tower will be connected to the mini-grid service.

Furthermore, the MTN agency has a genset for its own use but also serves as an informal Independent Power Producer (IPP). They consume 10 L/day (33 kWh/day), while at the time of visit they were charging 90 mobile batteries through LCD universal chargers that consume around 2 W, as shown below. Daily they can charge 270 batteries of 4 hours each, leading to 2.16 kWh/day of consumption.



Figure 5: LCD universal charger in Bissorã

Future commercial and productive uses reported are: a cinema, sewing machines, rice mills for the women association and refrigeration units.

The association of traders in Bissorã has expressed the desire to implement a central refrigeration point in the main market in order to offer refrigeration space for the traders (instead of each of them owing individual refrigerators). Thus, the market can be considered as an independent connection for 5 chest freezers. Moreover, at the moment there is no ice production unit in Bissorã and ice is imported from Bissau on daily basis. An estimation is that after the connection of the market to the mini-grid, they will acquire an ice-making machine in order to produce it locally.

Two user groups were identified with a potential of electricity usage for productive uses: the women association operating rice mills and the carpenters currently working with manual tools such as saws. While they didn't express immediate interest in switching to electric tools, the savings and income generation potential of such conversion could be assessed in more detail during next visits.

The following table list the potential commercial connections in Bissorã town:

Table 3: Businesses potentially to connect to the mini-grid

Businesses	Number
Shops	237
Restaurants and bars	18
Pharmacies	3
Veterinary	1
Guesthouses	1
Wood treatment workshop	1
Carpentry	3
Telecommunications towers	1
Grain mills	4
Cinema	1
Sewing machines	1
Market	1
TOTAL	272

3.3. Current situation of distribution grid

According to the available latest data of the project implementation, the distribution grid that has been in place is capable to connect at least 470 users, equal to the number of meters currently been purchased for the project. Nonetheless, the current length of the distribution grid does not pass through the whole town. Five out of 16 neighbourhoods are out of reach (namely Joaquim N'com/Argentina, Sintcham, Gã-Banana, Missira and Touba), which represent the 24% of the total population of Bissorã. This means that a universal connectivity could only be achieved with an extension of the distribution grid, something which costs around 20,000 € per kilometre.

4. Demand estimation

4.1. General assumptions

Based on the aforementioned information and TTA's methodology, a complete load profile has been assessed for Bissorã. The steps followed and main assumptions include:

- For the 59 potential end-users interviewed, the daily energy demand has been estimated in order to create the energy baseline of Bissorã (design demand). Then this is adjusted based on Bambadinca's data and TTA's experience.
- Lighting: For the total number of light bulbs observed during the visit of the 59 potential end-users, it is assumed a simultaneity factor of 50%
- Water pump: In order to calculate the electricity demand, it has been considered that the water necessities are 30 L/person/day (information collected from the end-user questionnaires). Assuming an average borehole depth of 25 m, the energy needed for pumping water is calculated based on the village's population and distributed across five hours within a day, from 10:00 to 15:00.
- Street lighting: It has been assumed one light of 40 W for every 16 households functioning from 18:00 to 6:00
- Utilisation factor of 70% has been considered
- Grain mills: There is no specific information of the 4-grain mills existing so assumptions have been made. It is considered that after the mini-grid operation, the grain mills will be electric of 1.1 kW. Half will produce 30 kg/day during 2 hours of functioning and half will produce 60 kg/day in 4 hours of graining.

- For all consumer types, a load profile is given according to TTA’s standardisation methodology of tariffs per type of connection and adapted for the specific conditions of Bissorã, with additional inputs from Bambadinca.
- For the market’s connection, it is assumed that there are 5 chest freezers consuming 2 kWh/day and an ice making machine of 1.1 kW working 5 hours per day.
- The interviewees were asked about the desired future loads. There was a lot of variation in the answer, ranging from 0% to a 3000% of difference between their current demand and their desired remand. In order to get as realistic results as possible for the energy baseline, it was assumed that the EDA of each customer for the design is up to double than their current declared demand

4.2. Individual load profiles

The individual load profiles used for each connection type are shown in Figure 6.




Figure 6: Individual load profiles for energy baseline

5. Energy baseline results

The energy baseline of Bissorã has been created taking into account three different scenarios, as described in the paragraphs below:

5.1. Base scenario

In this scenario the number of connections is equal to the number of meters already purchased for the project (470). This would be enough to connect 20% of the existing households (HH), 65% of the existing commercial users (CO) and all other aforementioned connections. The energy tiers (EDAs) assigned to each connection type are estimated from the current demand according to the end-user inquiries and TTAs experience.

The shares shown in Table 4 have been derived from surveys and from TTA's visit to Bissorã, where demand patterns for each customer group were estimated. In addition, the estimations have been validated by analysing real demand data from Bambadinca, where it was found that the average household consumes 0.87 kWh/day while an average shop consumes 1.37 kWh/day. It is expected that these customer groups will display similar average consumption figures in Bissorã.

For individual customers such as the guesthouse, wood treatment workshop and worship places, the direct information from the interviews has been used.

Table 4: Energy demand assessment under Base Scenario

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Households	basic	550	75%	203	111.650
	medium	1.650	20%	54	89.100
	high	3.850	5%	13	50.050
Commercial*	basic	550	40%	69	37.950
	medium	1.650	55%	94	155.100
	high	3.850	5%	8	30.800
Community buildings	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	1.650	33%	1	1.650
Education centres	basic	2.200	33%	4	8.800
	medium	4.400	33%	3	13.200
	high	7.150	33%	3	21.450
Churches	basic	2.200	50%	1	2.200
	high	7.700	50%	1	7.700
Mosques	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	2.200	33%	1	2.200
Wood processing factory	basic	150.000	100%	1	150.000
Health facilities	basic	16.500	100%	1	16.500
Guesthouse	basic	88.000	100%	1	88.000
Water Pump	basic	29.155	100%	1	29.155
Telecom Towers	basic	53.350	100%	1	53.350
Grain Mills	basic	2.200	50%	2	4.400
	high	4.400	50%	2	8.800

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Market	basic	15.500	100%	1	15.500
Street Lights	basic	38.945	100%	1	38.945
TOTAL energy					941 kWh/day

*Commercial: include pharmacies, shops, MTN agencies offering phone charging services, carpenters, restaurant and bars, vets and sewing machines

Considering a 60% plant performance ratio and 6 peak sun-hours, the total daily energy demand of 941 kWh/day (343 MWh/year) would require a **261kWp** PV plant installed capacity.

With an emission factor of electricity production with gensets equal to 0.8 kgCO₂eq./kWh¹, the savings in greenhouse gas (GHG) emissions would be 274.743 kgCO₂eq./year, in case all demand would be covered by diesel generators.

The load curve for the base scenario is shown in Figure 7 and the distribution of consumer type in Figure 8, demonstrating that in the base scenario, the majority of Bissorã consumption is due to commercial loads.




Figure 7: Bissorã load curve under Base Scenario

¹ EPA, 2014. Emission Factors for Greenhouse Gas Inventories.

Found at: https://www.epa.gov/sites/production/files/2015-07/documents/emission-factors_2014.pdf




Figure 8: Pie chart of consumer types under Base Scenario

5.2. Intermediate scenario

This scenario estimates the maximum number of connections that the 500 kWp mini-grid can cover only with solar power, based on the same distribution of connections as the base scenario. This could be achieved with 82% connectivity of the households and 100% connectivity of the commercial connections, as of their current number or a total of 1357 connections. The results are shown in Table 5.

Table 5: Energy demand assessment under Intermediate Scenario

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Households	basic	550	75%	794	436.700
	medium	1.650	20%	211	348.150
	high	3.850	5%	52	200.200
Commercial*	basic	550	40%	106	58.300
	medium	1.650	55%	145	239.250
	high	3.850	5%	13	50.050
Community buildings	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	1.650	33%	1	1.650
Education centres	basic	2.200	33%	4	8.800
	medium	4.400	33%	3	13.200
	high	7.150	33%	3	21.450
Churches	basic	2.200	50%	1	2.200
	high	7.700	50%	1	7.700
Mosques	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	2.200	33%	1	2.200
Wood processing factory	basic	150.000	100%	1	150.000
Health facilities	basic	16.500	100%	1	16.500

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Guesthouse	basic	88.000	100%	1	88.000
Water Pump	basic	29.155	100%	1	29.155
Telecom Towers	basic	53.350	100%	1	53.350
Grain Mills	basic	2.200	50%	2	4.400
	high	4.400	50%	2	8.800
Market	basic	15.500	100%	1	15.500
Street Lights	basic	38.945	100%	1	38.945
TOTAL energy					1.799 kWh/day

*Commercial: include pharmacies, shops, MTN agencies offering phone charging services, restaurant and bars, vets and sewing machines

Considering a 60% plant performance ratio and 6 peak sun-hours, the total daily energy demand of 1.799 kWh/day (657 MWh/year) would require a **500kWp** PV plant installed capacity.

With an emission factor of electricity production with gensets equal to 0.8 kgCO₂eq./kWh², the savings in greenhouse gas (GHG) emissions would be 525.279 kgCO₂eq./year, in case all demand would be covered by diesel generators.

The load curve for the intermediate scenario is shown in Figure 9 and the distribution of consumer type in Figure 10, demonstrating that under this scenario, the majority of Bissorã consumption is due to residential loads.




Figure 9: Bissorã load curve under Intermediate Scenario

² EPA, 2014. Emission Factors for Greenhouse Gas Inventories.

Found at: https://www.epa.gov/sites/production/files/2015-07/documents/emission-factors_2014.pdf




Figure 10: Pie chart of consumer types under Intermediate Scenario

5.3. Future scenario

The hypothesis assumed in this scenario are:

- The total number of households and commercial users increases by 10% as to the current situation.
- The connectivity rate of households is 90% and of commercial connections is 100%
- The average daily demand of the households and commercial connections increases by 20% regarding the demand in the base and intermediate scenarios.

The results of this scenario would be the connection of 1605 users as follows:

Table 6: Energy demand assessment under Future Scenario

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Households	basic	550	58%	746	410.300
	medium	1.650	37%	475	783.750
	high	3.850	5%	65	250.250
Commercial*	basic	550	25%	73	40.150
	medium	1.650	65%	188	310.200
	high	3.850	10%	29	111.650
Community buildings	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	1.650	33%	1	1.650
Education centres	basic	2.200	33%	4	8.800
	medium	4.400	33%	3	13.200
	high	7.150	33%	3	21.450
Churches	basic	2.200	50%	1	2.200
	high	7.700	50%	1	7.700
Mosques	basic	1.100	67%	2	2.200
	medium	1.100	0%	0	0
	high	2.200	33%	1	2.200

Type	Category	EDA (Wh/day)	Share	Number	Total EDA (Wh/day)
Wood processing factory	basic	150.000		1	150.000
Health facilities	basic	16.500	100%	1	16.500
Guesthouse	basic	0	100%	1	88.000
Water Pump	basic	88.000	100%	1	32.071
Telecom Towers	basic	32.071	100%	1	53.350
Grain Mills	basic	53.350	50%	2	4.400
	high	2.200	50%	2	8.800
Market	basic	4.400	100%	1	15.500
Street Lights	basic	15.500	100%	1	42.840
TOTAL energy					2.379 kWh/day

Considering a 60% plant performance ratio and 6 peak sun-hours, the 2.379 kWh/day (868 MWh/year) would require a **661 kWp** PV plant.

With an emission factor of electricity production with gensets equal to 0.8 kgCO₂eq./kWh, the savings in greenhouse gas (GHG) emissions would be 694.773 kgCO₂eq./year, in case all demand would be covered by diesel generators.

The load curve for the future scenario is shown in Figure 11.




Figure 11: Bissorã load curve under Future Scenario

The load curve of the Future Scenario has higher night loads than the one of the Base and Intermediate Scenario, due to the fact that the residential consumption which peaks at night is higher than the commercial and institutional I loads (Figure 12).




Figure 12: Pie chart of consumer types under Future Scenario

6. Conclusions

The energy baseline study considered various inputs of relevant projects in the country, in-house experience, as well as site visits in Bissorã in order to assess the potential of energy demand in the town. It was found that the 500 kWp installed of PV capacity are sufficient to cover, not only the demand of the initial 470 connections, but a total of more than 1300, depending on their size. Nonetheless, the distribution grid should be extended should a universal connection be opted for, since 24% of the population are physically excluded by the grid as it is at the moment.

Three scenarios were examined for the energy baseline taking into account the current number of energy meters, the possible number of connections in order to saturate the solar generation plant, as well as a future growth. The results of the three scenarios are summarised below.

Table 7: Summarised results of Energy Baseline

	Base scenario	Intermediate scenario	Future scenario
Connections	470	1.350	1.650
Daily demand	941 kWh/day	1.799 kWh/day	2.379 kWh/day
Necessary PV capacity	261 kWp	500 kWp	661 kWp
Emissions savings	274.743 kgCO ₂ eq/year	525.279 kgCO ₂ eq/year	694.773 kgCO ₂ eq/year

Annex: Interview results

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
1	Sadja Camará	Utility	Joaquim N'kom	Shared genset (7 h/day)	960.000	1.411.046	1.411.046	Seasonal	0,8	6,5	1,7
2	Sene Camará	Commercial (MTN agent)	Praça-Mercado	Private genset (5.5 kVA, 10 h/day)	534.500	270.000	349.000	Seasonal	20,8	21,4	21,4
3	Guerra Bidonga	Community building (Regional Director of Agriculture)	Pecuaría	Shared genset (7 h/day)	300.000	145.000	145.000	Stable	1,2	8,5	2,4
4	Abu Camará	House	Joaquim N'kom	Shared genset (7 h/day)	40.000	15.000	15.000	Stable	0,9	5,5	1,8
5	Agostinho B.Indjalé	House	Madina	PV & batteries (24 h/day)	60.000	-	-	Seasonal	2,1	5,3	4,1
6	Alassam Djaló	Commercial (shop)	Praça-Mercado	Shared genset (5 h/day)	210.000	20.000	20.000	Stable	2,4	2,8	2,8
7	Alfa Umaro Bary	Commercial (shop)	Praça-Mercado	Shared genset (7 h/day)	150.000	30.000	30.000	Seasonal	1,2	7,3	2,3
8	Alfa Umaro Djalo	House	Santa Luzia	Batteries (5 h/day)	130.000	15.000	15.000	Seasonal	1,2	7,6	2,4
9	Aruna Camara	House	Sintcham	Private genset (5.5 kVA, 10 h/day)	300.000	25.000	25.000	Seasonal	5,6	5,6	5,6
10	Augusta Biambi	House	Gã-Djugudé	Private genset (2.5 kVA, 2 h/day)	50.000	25.000	30.000	Seasonal	5,3	6,1	6,1

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
11	Bailo Ould Mohamed Ali Haidara	Commercial (shop)	Praça-Mercado	Shared genset (7 h/day)	210.000	25.000	25.000	Seasonal	2,1	2,6	2,6
12	Braima Camará	House	Braga	PV & batteries (7 h/day)	70.000	25.000	25.000	Seasonal	9,3	9,7	9,7
13	Braima Fati	House	Gã-Djugudé	Shared genset (7 h/day)	42.000	33.000	33.000	Seasonal	0,8	3,9	1,5
14	Abudo Pereira Bareto	Community building (Police)	Praça	Candles	-	44.000	44.000	Stable	0,7	6,2	1,4
15	Amadu Djau Djalo	Commercial (shop)	Praça	Shared genset (7 h/day)	700.000	24.000	24.000	Seasonal	6,0	6,0	6,0
16	Djibril Sidibe	Commercial (shop)	Santa Luzia	Shared genset (7 h/day)	162.000	210.000	210.000	Seasonal	1,9	5,7	3,8
17	Domengas M. S. Elena	House	Pecuaría	Shared genset (7 h/day)	120.000	28.000	28.000	Seasonal	5,7	8,3	8,3
18	Domingos Pereira	House	Braga	Shared genset (7 h/day)	60.000	73.000	73.000	Seasonal	0,8	1,3	1,3
19	Dumingos José Tchuda	House	Praça	Shared genset (8 h/day)	60.000	150.000	150.000	Seasonal	4,4	5,6	5,6
20	Eduardo Meuldo Barbosa sousa	House	Praça	Private genset (5.5 kVA, 8 h/day)	80.000	88.000	88.000	Seasonal	9,8	9,9	9,9
21	António Incude	Education centre (Liceu Regional de Bissorã)	Braga	Private genset (7 kVA, 4 h/day)	800.000	-	-	Seasonal	6,9	13,5	13,5
22	Alfa Conate	Commercial (Pharmacy)	Praça	Shared genset (7 h/day)	300.000	2.000	2.000	Seasonal	1,5	5,9	2,9

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
23	Cumando Mané	Commercial (Pharmacy)	Joaquim N'kom	Shared genset (7 h/day)	250.000	-	-	Seasonal	1,1	9,1	2,2
24	Mamadu Samba Cunate	Commercial (Pharmacy)	Praça	PV & batteries (24 h/day)	177.000	33.000	33.000	Seasonal	1,6	6,1	3,2
25	Fatumata Cande	House	Praça Mercado	Shared genset (7 h/day)	800.000	15.000	15.000	Seasonal	0,7	5,4	1,3
26	Fernando Mané	House	Gã-Banana	Shared genset (4 h/day)	25.000	3.000	3.000	Stable	1,5	14,4	3,0
27	Doctor Nhina Na Tum-na	Health facilities (Hospital)	Joaquim N'kom	PV & batteries (3.25 kWp, 3 h/day)	30.000	25.000	25.000	Seasonal	16,5	25,8	25,8
28	Dauda Fino Camara	Hotel	Praça	Private genset (15 kVA, 12 h/day)	600.000	-	25.000	Seasonal	87,5	89,1	89,1
29	Sulemane Mane	Hotel	Gã-Banana	Private genset (40 kVA, 5 h/day)	375.000	-	-	Stable	0,0	0,0	0,0
30	Iaia Camará	House	Joaquim N'kom	Shared genset (7 h/day)	50.000	33.000	33.000	Seasonal	3,2	9,4	6,5
31	Augusta Biambi	Education centre (Instituto de Formação dos Professores)	Praça	Private genset (7 kVA, 5 h/day)	2.712.500	11.800	11.800	Seasonal	2,2	2,6	2,6
32	Clontente N'cada	Church	Praça	Private genset (15 kVA, 5 h/day)	172.000	25.000	25.000	Seasonal	7,5	10,6	10,6
33	Roberto Nhanque	Church	Joaquim N'kom	Private genset (2.5	308.000	25.000	25.000	Seasonal	1,8	5,8	3,7

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
				kVA, 4 h/day)							
34	Jamila Gomes Semedo	Education centre (Jardim Irmã Da Lena)	Joaquim N'kom	Private genset (5.5 kVA, 4 h/day)	40.000	15.000	15.000	Seasonal	2,7	9,8	5,5
35	João R. Cardoso	House	Praça	-	125.000	25.000	25.000	Seasonal	6,6	7,8	7,8
36	M'baque Camará	Commercial (shop)	Praça	Shared genset (7 h/day)	180.000	15.000	15.000	Seasonal	0,9	3,0	1,7
37	N'famara Camara	Commercial (shop)	Praça	Shared genset (7 h/day)	500.000	15.000	15.000	Seasonal	5,4	5,4	5,4
38	Malam Cisse	House	Joaquin N'KOM	Shared genset (7 h/day)	65.000	15.000	15.000	Seasonal	2,8	4,1	4,1
39	Mamado Djau Seide	House	Lolé	PV & batteries (24 h/day)	60.000	15.000	20.000	Seasonal	1,0	3,1	2,0
40	Mamadu Boi Djaló	House	Joaquim N'com	PV & batteries (24 h/day)	166.000	71.000	71.000	Seasonal	1,8	10,1	3,6
41	Mamasamba Djalo	Commercial (shop)	Praça	Shared genset (7 h/day)	350.000	20.000	20.000	Seasonal	0,5	4,3	1,1
42	Mariato Saide	House	Pecuararia	Candles	50.000	15.000	15.000	Seasonal	2,3	4,3	4,3
43	Aladje Mamadu Camara	Mosque	Santa-Luzia	Shared genset (3 h/day)	-	15.000	15.000	Seasonal	1,7	3,0	3,0
44	Queba Seide & Salam Camara Almames	Mosque	Argentina	Candles	3.000	72.500	72.500	Seasonal	0,9	2,1	1,9
45	Braima Cisse	Mosque	Santa-Luzia 2	Outro	5.400	-	0	Seasonal	0,6	1,4	1,1

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
46	Nilci Ramos	House	Gã-Banana	Portable light	25.000	20.000	20.000	Seasonal	6,0	10,0	10,0
47	Quintino Andji	Commercial (Stationer shop)	Praça	Private genset (5.5 kVA, 7 h/day)	300.000	2.000	2.000	Seasonal	1,7	1,7	1,7
48	Isnaba Embadji	Commercial (Stationer shop)	Praça	Private genset (5.5 kVA, 7 h/day)	75.000	15.000	15.000	Seasonal	4,6	5,2	5,2
49	Saido Dumbia	Commercial (Stationer shop)	Praça	PV & Shared genset (7 h/day)	80.000	-	-	Seasonal	1,4	5,8	2,8
50	Queba Seide	House	Joaquim N'kom	Shared genset (7 h/day)	85.000	-	-	Seasonal	5,8	8,5	8,5
51	Quemo Fati	Commercial (MTN agent)	Gã-Banana	Private genset (7 kVA, 7 h/day)	3.150.000	15.000	15.000	Seasonal	1,5	8,2	2,9
52	Ricardo Dautarim Gomes Cacabra	Commercial (shop)	Praça	Private genset (7 kVA, 3 h/day)	55.000	53.000	53.000	Seasonal	1,9	4,1	3,8
53	Roberto Nhanque	House	Sintcham	PV & batteries (7 h/day)	80.000	2.000	2.000	Stable	0,7	6,3	1,3
54	Rucana Danfa	House	Braga	PV & batteries (24 h/day)	80.000	5.000	5.000	Seasonal	3,0	4,3	4,3
55	Seco Dembo	House	Joaquim N'kom	Portable light	50.000	3.000	3.000	Seasonal	0,3	4,0	0,5
56	Suleimane Djaló	Commercial (shop)	Praça	Private genset (2.5 kVA, 8 h/day)	210.000	68.000	68.000	Seasonal	1,6	1,6	1,6

	Name	Connection type	Neighbourhood	Current energy supply	Monthly income (CFA/month)	Actual electricity expenses (CFA/month)	Available electricity budget (CFA/month)	Seasonality	Current estimated demand (kWh/day)	Future demand - Desired (kWh/day)	Future demand - Adopted (kWh/day)
57	Tcherno Só	Commercial (shop)	Praça	Shared genset (7 h/day)	500.000	25.000	25.000	Seasonal	0,5	2,3	1,1
58	Tomas Pedro Vaz	Community building (Court)	praça	-	600.000	-	-		0,6	16,0	1,2
59	ussuman marna	Wood saw	Lolé	Private genset	335.000	35.000	25.000	Seasonal	3,5	7,9	7,1
60	ussuman marna	House	Lolé	PV & batteries (24 h/day)	300.000	3.000	3.000	Seasonal	0,2	0,6	0,3